



DESIGN GUIDELINES FOR FIRE SAFETY

TABLE OF CONTENTS

| | |
|---|---|
| DESIGN GUIDELINES FOR FIRE SAFETY | 1 |
| TABLE OF CONTENTS | 1 |
| I. GENERAL | 2 |



I. GENERAL

- A. Fire Lanes shall not be less than twenty feet wide.
- B. Fire Lanes vertical clearance shall not be less than thirteen feet and six inches
- C. Dead-end Fire Lanes in excess of 150 feet shall be provided with an approved area for turning around Fire Apparatus
- D. The required turning radius for the Fire Trucks is 55 feet.
- E. Markings and signs shall be provided for Fire Lanes
- F. Fire lanes must be able to support the weight of the largest fire truck (86,000 pounds)
- G. Fire alarm panels should not be put in closets that have other uses such as House Keepers and communication.
- H. If the building has a sprinkler system or standpipe a PIV must provided
- I. The purchase and installation of fire extinguishers shall be included as part of the cost of each project.

(END OF SECTION)