



I. UNC Chapel Hill Control Standards - Index

A. CONTROL GUIDE SPECIFICATIONS

Division 230000 BAS Specifications Zip File [Version Nov 2016](#) contains;

1. UNC Master Preface - Preface and Implementation Guidance to the Design Engineer
2. 230900 - Building Automations Systems (BAS) General
3. 230801 - BAS System Commissioning
4. 230901 - BAS Basic Materials, Interface Devices, and Sensors
5. 230903 - BAS Field Panels
6. 230904 - BAS Communication Devices
7. 230905 - BAS Software and Programming
8. 230906 - Operator Interface.pdf - BAS Local Operator Interface
9. 230993 - Sequence of Operations

B. CONTROL DRAWINGS

Note: Contact the UNC Commissioning Coordinator/Engineer for the AutoCAD version of specific schematics.

BAS PDF Drawings Zip File [Version Nov 2016](#) contains

1. T-1.00 Title Sheet - List of Drawings.pdf
2. C-0.00 Symbol - DDC Function Block Logic Symbols and Control Symbols
3. C-1.00 Single Duct VAV AH With Preheat CHW Coil, No Return Fan
4. C-1.01 Single Duct VAV AH with Preheat, CHW Coil and Return Fan
5. C-1.01a Single duct VAV AH with Preheat, CHW Coil 7 Return Fan W/Unit Exhaust at Min OA
6. C-1.02 Single Duct VAV AH with Preheat and CHW Coil, MIN OA Damper, No Return Fan
7. C-1.03 Single Duct CV AH with Preheat, CHW and Reheat Coil, MIN OA Damper and Return Fan
8. C-1.04 Single Duct CV AH with Preheat, CHW and Reheat Coil, MIN OA Damper, C02 Ventilation and Return Fan
9. C-1.05 100% OA CV AH with Heat Recovery, Preheat and CHW Coil
10. C-1.06 100% OA VAV AH With Preheat and CHW Coil, Steam Humidifier
11. C-1.07 Single Duct CV AH with Preheat and CHW Coil, MIN OA Damper and Return Fan
12. C-1.08 Single Duct CV AH with Preheat and CHW Coil, MIN OA Damper, No Return Fan
13. C-1.09 Dual VAV AH HW Preheat CHW Coil and Return Fan
14. C-1.09a Dual VAV AH Control, With Unit Exhaust At Min OA Flow
15. C-1.10 Single Duct CV AH Preheat and CHW Coil
16. C-1.11 100% OA CV AH With Heat Recovery, Face and Bypass Steam, CHW Coil and Steam Humidifier
17. C-1.12 Single Duct CV-VSD AH With Preheat and CHW
18. C-2.00 Single Duct VAV Box (Cooling Only)
19. C-2.01 Single Duct VAV Box (with HW Reheat Control)
20. C-2.01a Single Duct VAV Box (With HW Reheat Control) W/Heating Min Flow Setpoint
21. C-2.02 Duct Mounted HW Reheat Coil
22. C-2.03 Dual Duct VAV Box
23. C-2.04 Lab VAV Supply and Exhaust Flow Tracking
24. C-2.05 Lab Flow Tracking with Hood
25. C-2.06 Lab Flow Tracking with Hood and Snorkel
26. C-2.07 Lab VAV Flow Zone – Multi Zone
27. C-2.07 Lab CV Supply and Exhaust Zone
28. C-3.00 Steam to HW Converter with CV Pumps



29. C-3.01 Steam to HW Converter with VV Pumps
30. C-3.02 Process CHW Loop
31. C-3.03 Glycol heat recovery loop
32. C-4.00 Redundant CV Exhaust Fan Control for Manifold Exhaust Lab Systems
33. C-4.01 Redundant VAV Exhaust Fan Control For Manifold Exhaust Lab Systems
34. C-4.02 Fan Coil Units
35. C-4.03 Electric (or Hydronic) Unit Heater
36. C-4.04 Generator Exhaust Control
37. C-4.05 Miscellaneous Controls (Humidifier, Small Exhaust Fan, Etc.)