


- NOTES
1. Locate down stream duct static pressure pick-up tube approximately 2/3 down duct. See floor plans for location.
  2. Provide communications interface to the control system for diagnostic point information. Refer to points list for required points to be mapped.
  3. Provide multiple Freezestats as required to achieve 3% of element for each 3 sq ft of coil face area.
  4. Provide CHW/Temp/Pressure and sensor on all units with coil face area greater than 10 sq ft.
  5. Coordinate with mechanical design to ensure adequate straight lengths of duct and proper range on the sensor. Fan AFMS may be duct or inlet type, see plans for demand ventilation.
  6. Provide Return Air or Space CO2 sensors for demand ventilation applications only.
  7. Where applicable per mechanical design.
  8. See sheet C4.05 Miscellaneous Controls for additional equipment details.
  9. Reset values shown should be adjusted for optimized building and energy performance.

SINGLE DUCT VAV AH WITH PREHEAT, CHW COIL & RETURN FAN W/UNIT EXHAUST AT MIN OA FLOW



POINTS LIST						
ADDRESS	POINT DESCRIPTION	POINT TYPE				REMARKS
		DI	AI	DO	AO	
	Supply Fan S/S		*			
	Supply Fan Status	*				
	SE VSD Alarm			*		Interlock Point
	Supply Fan Speed			*		
	Return Fan S/S		*			
	Return Fan Status		*			
	RF VSD Alarm			*		Interlock Point
	Return Fan Speed		*			
	DD Static Press		*			See Note 1
	Supply Temp		*			
	PH Coil DAI		*			
	Freezestat		*			
	Mixed Air Temp		*			
	Return Air Temp		*			
	Return Air Humidity		*			
	Return Air CO2		*			See Note 6
	Space CO2		*			See Note 6
	CHW Valve		*			
	CHW Temp		*			See Note 4
	HW Valve		*			
	Economizer		*			
	OA Flow		*			
	Supply HI Static		*			
	Supply LO Static		*			
	Return HI Static		*			
	Return LO Static		*			
	Supply Air Flow		*			
	Return Air Flow		*			
	Smoke/Fire Alarm		*			
	Circ Pump S/S		*			See Note 7
	Circ Pump Status		*			See Note 7
	VFD Alarm/Fault		*			Interlock Pt. (Op. on VFD)
	VFD Fault Code		*			Interlock Pt. (Op. on VFD)
	VFD Spd Feedback		*			Interlock Pt. (Op. on VFD)
	VFD RV		*			Interlock Pt. (Op. on VFD)
	VFD in Bypass		*			Interlock Pt. (Op. on VFD)

LOGIC VARIABLES

BINARY	ANALOG	DESCRIPTION
Occ		ON WHEN OCCUPIED MODE ACTIVE
RUN		ON WHEN UNIT COMMAND TO START
SSO		ON WHEN SUPPLY FAN ENERGIZED AND STATUS PROVEN
RRO		ON WHEN RETURN FAN ENERGIZED AND STATUS PROVEN
LAOCO		ON WHEN OA COMMONS ALLOW ECONOMIZER CONTROL
SLAY		ON WHEN THE SUPPLY HI PRESSURE ALARM IS ACTIVE
SHRZ		ON WHEN THE SUPPLY LO PRESSURE ALARM IS ACTIVE
FRZ		ON WHEN FREEZE/ST IS IN ALARM
FTF		ON WHEN FIRE ALARM IS ACTIVE
STFT		ON WHEN UNIT SHUTDOWN ALARM IS ON
LSST		VARIBLE OCUATED VALUE OF HIGHEST SPACE TEMPERATURE
SENST		VARIBLE OCUATED VALUE OF SUPPLY AIR FLOW (CFM)
CAV		VARIBLE WALE OF OUTSIDE AIR TEMPERATURE
SAV		VARIBLE WALE OF SUPPLY AIR TEMPERATURE
FHT		VARIBLE WALE OF PREHEAT AIR TEMPERATURE
MAV		VARIBLE WALE OF MIXED AIR TEMPERATURE
MINOA		VARIBLE WALE OF MIN OA DUREPS POSITION (BASED ON OA FLOW PD OUT)
DISSD		VARIBLE OCUATED WALE OF DISCHARGE TEMPERATURE SETPOINT
COPO		VARIBLE OCUATED WALE OF CHW VALVE POSITION
HEPO		VARIBLE OCUATED WALE OF HEAT WALE POSITION
EEPO		VARIBLE OCUATED WALE OF ECONOMIZER PD OUTPUT
DAFLD		VARIBLE WALE OF OUTSIDE AIR FLOW (CFM)
DAFSD		VARIBLE OCUATED WALE OF CHW VALVE POSITION FOR DEMANDVENTION
DAFSD		VARIBLE OCUATED WALE OF OA FLOW SETPOINT

ELECTRIC LADDER DIAGRAMS

